



PfB

Prüfzentrum für Bauelemente
Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 2021-27-0226-C2

Version 1.en

Applicant

Işıldak İnşaat Taah. Tic.A.Ş.
Mutlukent Mah.1986 Sk. No:20
Ümitköy-Ankara-Türkiye

Test date

March 25, 2021

Product name

Albert Genau Tiara Int.08 & Balumax Int.08

Type

Fully glazed sliding window with glazed panels made of 8 mm tempered glass as balcony glazing with stacking area, freely selectable number of glazed panels (3 panels), the first glazed panel opens on hinges with bottom balcony system made of single glazed (4.4.2 tempered laminated glass)

Dimension

(W x H) max. 2400 mm x 2500 mm

Performance

According to test report No. 2021-27-0226-B2 from April 28, 2021:

Air permeability according to EN 12207 Class 2

Water Tightness according to EN 12208 Class 2A

Impact Resistance according to EN 14019 Class I1/E3

Measurement of deflection
According to EN 12211/12210

+1200 Pa: 10,39 mm.
-1200 Pa: 12,44 mm.

Repeated pressure
According to EN 12211/12210

+600 Pa / -600 Pa

Safety test
According to EN 12211/12210

+1800 Pa / -1800 Pa

Validity Period of validity of standarts


Y. Altug
Technical Manager



April 28, 2021

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0
Telefax +49 (0) 80 36 / 67 49 47 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Sparkasse Rosenheim
Bankleitzahl 711 500 00
Kontonummer 500 556 741
Steuer-Nr.156/172/13009
USt-IdNr. DE245353602



Anerkannte Prüfstelle
Landesbauordnung
BAY 33

Notified Body
No. 1644