



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 18/04-A002-C1

Version 1.en

Applicant

Işıldak İnşaat Taah. Tic.A.Ş.
Mutlukent Mah.1986 Sk. No:20
Ümitköy-Ankara-Türkiye

Test date

May 30, 2018

Product name

Albert Genau Slidemaster Twin

Type

Fully glazed sliding door with glazed panels made of double glass (3 panels)(4-12-4 / Tempered)

Dimension

(W x H) max. 2400 mm x 2200 mm

Performance

According to test report No. 18/04-A002-B1 from June 11, 2018:

Air permability according to EN 12207

Class 2

Water Tightness according to EN 12208

Class 3A

Impact Resistance according to EN 14019 **Class I2**

Measurement of deflection

+1600 Pa: 54,5 mm.

According to EN 12211/12210 (class 4)

-1600 Pa: 53,9 mm.

Repeated pressure

+800 Pa / -800 Pa

According to EN 12211/12210 (class 4)

Safety test

+2400 Pa / -2400 Pa

According to EN 12211/12210 (class 4)

Validity

Period of validity of standarts

Y. Altuq
Technical Manager



June 25, 2018

