



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 2021-27-0226-C3

Version 1.en

Applicant

Işıldak İnşaat Taah. Tic.A.Ş.
Mutlukent Mah.1986 Sk. No:20
Ümitköy-Ankara-Türkiye

Test date

March 25, 2021

Product name

Albert Genau Slider Next 10 All Glass

Type

Fully glazed sliding door with glazed panels made of 10 mm tempered glass (3 panels)

Dimension

(W x H) max. 2400 mm x 2200 mm

Performance

According to test report No. 2021-27-0226-B3 from April 28, 2021:

Air permability according to EN 12207 Class **1**

Water Tightness according to EN 12208 Class **2A**

Impact Resistance according to EN 14019 Class **I4/E4**

Measurement of deflection
According to EN 12211/12210

+1600 Pa:	38,01 mm.
-1600 Pa:	37,06 mm.

Repeated pressure
According to EN 12211/12210

+800 Pa / -800 Pa

Safety test
According to EN 12211/12210

+2400 Pa / -2400 Pa

Validity Period of validity of standarts


Y. Altug
Technical Manager



April 28, 2021

