



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 2021-27-0226-C4

Version 1.en

Applicant

Işıldak İnşaat Taah. Tic.A.Ş.
Mutlukent Mah.1986 Sk. No:20
Ümitköy-Ankara-Türkiye

Test date

March 26, 2021

Product name

Albert Genau Vertiflex Clean Twin

Type

Vertical-Sliding guillotine window, with one fixed&openable and two sliding double glazed panels made of 5-12-5 mm tempered glass, panels controlled by electric drive and remote control

Dimension

(W x H) max. 3000 mm x 2500 mm

Performance

According to test report No. 2021-27-0226-B4 from April 28, 2021:

Air permability according to EN 12207 Class **3**

Water Tightness according to EN 12208 Class **3A**

Impact Resistance according to EN 14019 Class **I3/E3**

Measurement of deflection
According to EN 12211/12210

+1800 Pa:	59,35 mm.
-1800 Pa:	59,72 mm.

Repeated pressure
According to EN 12211/12210

+900 Pa / -900 Pa

Safety test
According to EN 12211/12210

+2700 Pa / -2700 Pa

Validity Period of validity of standarts

Y. Altug
Technical Manager



April 28, 2021

